LPCB®

Certificate of Product Approval

Assan Panel UK

CERTIFICATE NUMBER	ISSUE	COMPANY ADDRESS
1913a	01	Unit 11 Gostling Avenue Stowmarket Ipswich IP14 5YQ

The named company is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

PRODUCTS	STANDARDS
Sandwich Panel (refer to Appendix for details)	LPS1181 Part 1: Issue 1.2 Series of Fire Growth Tests for LPCB Approval and Listing of Construction Product Systems. Part 1: Requirements and Tests for Built-up Cladding and Sandwich Panel Systems for use as the External Envelope of Buildings

This certificate is maintained and held in force through regular surveillance activities.

Signed for BRE Global Ltd.	Karen Coull Certification Manager	04 September 2026 Date of this Issue

04 September 2026
Date of First Issue

This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com). To check the validity of this certificate and appendix please scan the QR tag, visitwww.redbooklive.com or contact us.

LPCB® is a registered trademark of the Building Research Establishment Ltd.

BRE Global, Bucknalls Lane,
Watford,WD25 9XX
T: +44 (0)333 321 8811
E: enquiries@bregroup.com

Copyright © BRE 2026 All Rights Reserved.

E ÖZEL , Bu dokuman Assan Panel A.S.ye ait olup, tum haklari saklidir. Basili oldugu durumlarda kontrolsuz kop

LPCB®

Appendix to Certificate No: 1913a

ISSUE
01

Assan Panel UK

Sandwich Panel

Product Name	Specification Thickness (mm)	Specification Wall panel orientation (H/V) (note 1)	Fire Resistance Integrity / Insulation	LPS 1181 – 1 Grade	Core Material	LPCB Ref. No
N4 (Wall)	40 to 160	H/V	-	EXT-B	Smartcore PIR	1913a/01
N4 (Roof)	40 to 160	-	-	EXT-B	Smartcore PIR	1913a/01

Notes:

1. Wall panel orientation, Horizontal or Vertical (H/V), relates to the long joint orientation.
2. LPCB ref.1913a/01, N4 Panels require stitching with 5.5x25mm SFS Brand self drilling screws externally at 250mm vertically and 500mm centres horizontally. Fasteners are SFS Brand 6.3mmx190mm for walls and 6.3mmx220mm for roof to purlins. Requires 6.3x230mm SFS Brand Screws to Heavy Steel/PFCs.
3. Approved Manufacturer.

   The following company manufacture the products listed on this certificate. The company is audited by LPCB to ensure the product certification requirements are met.

   Assan Panel UK (LPCB ref. C1913)
   Unit 11,
   Gostling Avenue
   Stowmarket,
   Ipswich
   IP14 5YQ
   UK

This certificate is maintained and held in force through regular surveillance activities.

Signed for BRE Global Ltd.	Karen Coull Certification Manager	04 September 2026 Date of this Issue

04 September 2026
Date of First Issue

This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com). To check the validity of this certificate and appendix please scan the QR tag, visitwww.redbooklive.com or contact us.

LPCB® is a registered trademark of the Building Research Establishment Ltd.

BRE Global, Bucknalls Lane,
Watford,WD25 9XX
T: +44 (0)333 321 8811
E: enquiries@bregroup.com

Copyright © BRE 2026 All Rights Reserved.

E ÖZEL , Bu dokuman Assan Panel A.S.ye ait olup, tum haklari saklidir. Basili oldugu durumlarda kontrolsuz kop